


Technical Pre-Bid Queries

Tender No-TPNODL/OT/2020-21/005 Dtd.28.04.2021

Reply to Pre-Bid Queries for Performance based Annual Operation and Maintenance contract for 33/11 KV Grids & 33KV Feeders for 3Years in TPNODL Area

| Sr. No. | Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No | Description as per Bid Document | Query / Clarification / Deviation | Reply from TPNODL |
|---------|---|---|--|---|
| 1 | 2 | 3 | 4 | 5 |
| 1 | Page no. 31(B) Operation of PSS (IX) | (IX) Service to be provide 24X7 days. | | Service to be provide 24X7 days. |
| | | (XIV) No where a single person (Technical) shall be allowed to work on any electrical appatus/line in a shift.He should always be assisted by at least 01 person (Non-Tech) while on work in a shift. | on page no.59 it is menionted that PSS opration staff the manpower details shows less no.of unskilled as compare to the skilled in all the circles. The reliever for unskilled manpower is not taken into consideration. | 6 persons are working 3 shifts comprise 1 skilled & 1 unskilled per shift. One skilled person may be considerd as reliever. |
| 2 | Page No. 27- Aggressive tree trimming | Aggressive one time trace trimming would be arranged by BA by Providing two teams with a vehicle in each circle. | No. of person to be deployed in one teams For how many days/months/we have to deplay these teams and vehicle | No additional team need to be deployed for tree trimming. Maintainence team would be engaged in tree trimming itself. |
| 3 | Page No. 29 (Y) Maintanance 01 33/11 KV PSS | Providing foldable FRP ladder for carrying out work at height at least 2 Nos. of FRP ladder per section shall always be available. | The size of ladder will be 18X18 feet or 14X14 feet. How many section are these in each circle. | Working Height may go up to 33 feet. Hence, ladder size be taken accordingly. Division may be considered in place of section. |
| 4 | Page No.60 | Bolero back side covered (for maintanance & testing purpose) shall be capable of carrying/sitting of 8 persons 01 driver and requisite material. | Is it a loading vehicle? Please make it clear what type make vehicle we have to provide. | Bolero pick up / equivalent vehicle back side covered (for maintanance & testing purpose) shall be capable of carrying/sitting of 7/8 persons 01 driver and requisite material. |
| 5 | Page no 58 , Annexure-V ,regarding organisation Chart | | Total manpower required for team formation under the heading 'distribution of manpower' for all the circle is 305 whereas minimum manpower required in table A (Maintenance & testing staff)are 254 ,which one to be considered for pricing | Total numbers would come as 254 as no reliever required for maintainence. Also, no driver required for bikes and reliever considered for breakdown vans as number is very less (6 nos of breakdown vans). |
| 6 | Page no 60 | | Separate vehicle is given for each testing teams .kindly clarify whether this is included in the total vehicle requirement of 44 as given in the table | 33kv line mantainence =16, PSS mantainence=12, Testing=10 and 24 hrs breakdown vehicle. I hope its clear now. |


GM (Contracts)
TPNODL, Balasore