

# Tata Power Northern Odisha Distribution Limited, Balasore

## Pre-Bid Query Response NIT-027, 11, 33kV CT/PT

Item	Requirement as per Tender	Amendment Proposed	Justification	TPNODL Remarks
12kV CT 800-400-200/1-1-1A	Given in TS: Vk>=250 V (At 200/1A) and Vk>=500V (At 400/1A)	Vk is not given for 800/1 A,  So Vk shall be: $Vk \geq 1000/500/250$ V	As you have not given Vk for 800 /1 ratio, we have assumed 1000V. Kindly confirm the same.	YES. Vk>=1000V (At 400/1A)
	<b>Given in TS:</b> Rct=5 Ohm	But it is not mentioned that <b>5 Ohm is for which ratio.</b>  So Rct shall be : Rct@75°C <= 20/10/5 Ohms <b>(if Rct 5 Ohm is considered @ 200/1 A)</b>	As you have not given Rct of all ratios, we have assumed <b>20/10/5</b> ohms. Kindly confirm the same.	Yes it is in proportion with <b>Rct 5 Ohm is considered @ 200/1 A)-</b>  RCT 5 OHM= 200/1 RCT 10OHM=400/1 RCT 20 OHM= 800/1
	Given in TS: Maximum excitation current (Ie) @ Vk/2 shall not be less than 30mA.	But as per IS , maximum excitation current shall be " <b>less than or equal to</b> " the specified value.  So maximum excitation current shall be: <b>Ie@Vk/2 &lt;= 30mA</b> ( At 200/1, 400/1A, 800/1A)	We have assumed Rct<= 5 ohms at 200/1A ratio and accordingly maximum excitation current assumed is Ie@Vk/2<=30 mA at 200/1A,400/1A,800/1A. Kindly confirm the same.	Maximum excitation current (Ie) @ Vk/2 shall not be <b>greater</b> than 30mA.
33 CT 400-200-100/1-1-1A	<b>Given in TS:</b> Vk>=250 V (At 200/1A) and Vk>=500V (At 400/1A)	Vk shall be $Vk \geq 500/250/125$ V	We have assumed $Vk \geq 125V$ at 100/1 A ratio. Kindly confirm the same.	$Vk \geq 125$ V (At 100/1A) $Vk \geq 250$ V (At 200/1A) and $Vk \geq 500V$ (At 400/1A)
	<b>Given in TS:</b> Rct=5 Ohm	Rct shall be : Rct@75°C <= 10/5/2.5 Ohms ( <b>if Rct 5 Ohm is considered @ 200/1 A</b> )	We have assumed Rct<=5 ohms at 200/1A ratio, so Rct at others taps shall be assumed as <b>10/5/2.5</b> ohms. Kindly confirm the same.	RCT=2.5 Ohm, 100/1 A RCT=5 Ohm, 200/1 A RCT=10 Ohm, 400/1 A

	<b>Given in TS:</b> Maximum excitation current (I <sub>e</sub> ) @ V <sub>k</sub> /2 shall not be less than 30mA.	Maximum excitation current, I <sub>e</sub> @V <sub>k</sub> /2 ≤ 30mA ( At 100/1, 200/1A,4800/1A)	We have assumed maximum excitation current I <sub>e</sub> @V <sub>k</sub> /2 ≤ 30mA at 100/1A,200/1A,400/1A Kindly confirm the same.	Maximum excitation current (I <sub>e</sub> ) @ V <sub>k</sub> /2 shall not be <b>greater</b> than 30mA.
12kV CT 600-300-150/1-1-1A	Specification of Core details is not given in the TS.	Kindly provide the core details of CT 600-300-150/1-1-1A	You have not given core details in TS, so kindly provide the same.*	
	TECHNICAL SPECIFICATION, CLAUSE No 4(i). & 5 (f), PAGE NO. 4 OF 19	4.0 i) System fault level - 26.3 KA for 3 sec. 5.0 (f) Rated Short time withstand current - 25KA RMS for 3 sec	Please confirm the short circuit level of CT, we are assuming Short circuit level at 25 KA for 3 sec	<b>As per Tender Specifications,</b> Short circuit level at 25 KA for 3 sec

*Core details of CT 600-300-150/1-1-1A	Metering	PROTN	PS
Current ratio	(As per BPS)		
Accuracy class	0.2(33)0.5(11)	5P20	PS
Burden (VA)	30	30	
Instrument security Factor	≤5	-	
Accuracy Limit Factor	-	≥20	
Knee point voltage			V <sub>k</sub> > 750V at 600/1A & ≥ 325V at 300/1 & ≥ 187.5V to 150/1 Maximum exciting current at V <sub>k</sub> /2 shall not be greater than 30mA. R <sub>ct</sub> = 15/7.5/3.75 for 600-300-150/1-1-1A